

POWER VERIFICATION OF ENERGY-INTENSIVE EQUIPMENT						Date:	
Applies to flow-type equipment subject to the procurement instruction for flow devices above 30 kW, considering energy efficiency.							
Subject:						Organisational unit:	
						Device number:	
						Prepared by:	
<p>Measurements should be performed under the most common operating conditions. If a measurement at any point is not possible, the reason must be stated in the "Comments" column.</p> <p>Only non-shaded cells are to be filled in. The shaded cells are automatically filled in once the relevant data has been entered.</p>							
Measurement points	Measurement data			Manufacturer's data	Power consumption deviation	Measurement result	Comments
	Capacity	Frequency*	Power consumption	Power consumption			
1	m3/h	Hz	kW	kW	%		
2*		50**					
<p>* Completion of the column/row is only valid for a device with inverter. In other cases, please enter "device without frequency inverter" in the "Comments" column.</p> <p>** Preset value.</p>							
RESULT OF VERIFICATION							